

## Compliance Statement

## Screened Category 7 ISO/IEC, EN & Enhanced TIA/EIA Communication Cable

**R&M Freenet, Type R35060** 

Category 7, Individual Foil and Overall Braid Screened 100 Ω, 4 Twisted Pairs, 23 AWG, Fire Retardant, LSFR0H, Copper Cable

Reichle & De-Massari AG
Binzstrasse 31
CHE-8622 Wetzikon, Switzerland

Compliance Statement No. 98163G

This Screened ISO/IEC, EN & Enhanced TIA/EIA Communication Cable has been tested by 3P Third Party Testing and complies with the Category 7 performance requirements of 2nd edition ISO/IEC Generic Cabling Standard 11801, CENELEC Generic Cabling Standard EN 50173-1 and IEC Cable Standard 61156-5, the Category 6 requirements of ANSI/TIA/EIA Generic Cabling Standard 568-B.2-1 (modified to cover individual foil and overall braid screened cables) and the requirements of 2nd edition CENELEC Cable Standard EN 50288-4-1. Fire Retardancy is verified according to IEC 60332-3, Cat. C:1992. The cable has EMC Performance Rating 9. The Compliance Statement may be suspended or withdrawn if cable fails to pass a Maintenance Testing performed at 6 or 12 months intervals.

| Н | oers | hol | m, | 1( | ) ] | -e | bu | ıar | y ∠ | 200 | )6 |  |
|---|------|-----|----|----|-----|----|----|-----|-----|-----|----|--|
|---|------|-----|----|----|-----|----|----|-----|-----|-----|----|--|

Ole hankly

Ole Lambertsen Test Responsible Hoersholm, 10 Febuary 2006

Poul Villien

Coordinating Manager